

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

| | |
|---|----------------|
| THE APPLICATION OF UNION COUNTY WATER) | |
| DISTRICT FOR A DEVIATION FROM 807 KAR) | |
| 5:066, SECTION 5(4) REGARDING WATER) | CASE NO. 10400 |
| STORAGE) | |

O R D E R

By letter received September 30, 1988, Union County Water District ("Union County") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to insure a minimum of 1 day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Union County's current water storage capacity is 411,600 gallons.
2. Union County's average daily water usage including unaccounted-for-water is 592,493 gallons.
3. Union County is pursuing alternative sources of financing and will apply to Farmers Home Administration for funds to construct additional water storage tanks.
4. Because of the time needed to plan, finance and implement a program to construct water storage facilities, Union County should be given until March 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:

1. Union County be and it hereby is given until March 1, 1992 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Union County shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to March 1, 1992.

Done at Frankfort, Kentucky, this 3rd day of February, 1989.

PUBLIC SERVICE COMMISSION


Chairman


Vice Chairman


Commissioner

ATTEST:

Executive Director